

Government Of India
Bhabha Atomic Research Centre
Fire Service Section
Trombay

Ref.: FSS/Maint./12/2021/202

26th April, 2021

Sub. : **First Aid Fire Fighting Extinguisher's Periodical Inspection And Maintenance Report Of A.E.C. SCHOOL NO - 4, ANUSHAKTI NAGAR**


The periodical inspection & maintenance report of first aid fire fighting extinguishers installed at **A.E.C. SCHOOL NO - 4, ANUSHAKTI NAGAR** has been carried out by fire service section, and detailed report is attached herewith.



(R. S. Agrahari)
Dy. Chief Fire Officer

To

The Principal,
A.E.C. School No. - 4,
Anushakti Nagar,
Mumbai - 400 094


Mr. VP / Mr. HM /
Office
03/5/2021

0/0

Government of India
Bhabha Atomic Research Centre
Fire Service Section
Trombay

26th April, 2021

**Fire Extinguisher Inspection Report Of
A.E.C. SCHOOL NO - 4, ANUSHAKTI NAGAR**

Sr. No.	Extinguisher No.	Type	Cap.	Date Of Checking	Location	Remark
01	BARC/FS/SP/W -276	SP WT	9 Ltr	01.04.21	Office Gr. Floor	OK
02	BARC/FS/SP/ W - 277	SP WT	9 Ltr	01.04.21	Staff Room 1 st Floor	OK
03	BARC/FS/SP/ W - 471	SP WT	9 Ltr	01.04.21	Exam room 1 st floor	OK
04	BARC/FS/SP/ W - 472	SP WT	9 Ltr	01.04.21	Library Gr. floor	OK
05	C & S - 3922 T.T.P. - 34	CO ₂	6.7 Kgs	01.04.21	Chemistry Lab	OK
06	C & S - 3892 T.T.P. - 40	CO ₂	6.7 Kgs	01.04.21	Biology Lab, 1 st floor	OK
07	BARC/FS/CO ₂ - 252	CO ₂	4.5 Kgs	01.04.21	Principal room Gr.floor	OK
08	BARC/FS/CO ₂ - 253	CO ₂	4.5 Kgs	01.04.21	Computer room Gr.floor	OK
09	BARC/FS/CO ₂ - 254	CO ₂	4.5 Kgs	01.04.21	Physics lab. 2 nd floor	OK
10	BARC/FS/CO ₂ - 255	CO ₂	4.5 Kgs	01.04.21	Sitting. Room 2 nd floor	OK
11	BARC/FS/DCP/ABC - 24	SP ABC	9 Kgs	01.04.21	Chemistry Lab. Gr.floor	OK

Note: For Any Information Please Contact Fire Service Maintenance Office, On Extn. 20510.

26/4/21
A. G. Mishra
(S. S. Agrahari)

R. S. Agrahari
26/4/21
(R. S. Agrahari)
Dy. Chief Fire Officer

To
The Principal,
A.E.C. School No. - 4,
Anushakti Nagar,
Mumbai - 400 094