LICHENS ENVIRONMENT PVT LTD.

ENVIRONMENT CONSULTANT & MANUFACTURERS OF RO, DM, PORTABLE STP, ETP, CETP, LANDSCAPING, RAIN WATER HARVESTING

School no. 3

Sr.no.	Name of Test	Unit	Result	Limit (Min-Max)
1	Odour	---------	Odourless	Agreeable
2	pH value	----------	8.32	6.5-8.5
3	Total Dissolve Solids	Mg/L	160	Max 1500
4	Turbidity	NTU	2.15	Max 10
5	E-coli	(cfu)	0	0

School no. 4

Sr.no.	Name of Test	Unit	Result	Limit (Min-Max)
1	Odour	---------	Odourless	Agreeable
2	pH value	----------	8.15	6.5-8.5
3	Total Dissolve Solids	Mg/L	290	Max 1500
4	Turbidity	NTU	1.01	Max 10
5	E-coli	(cfu)	0	0

School no. 5

Sr.no.	Name of Test	Unit	Result	Limit (Min-Max)
1	Odour	---------	Odourless	Agreeable
2	pH value	----------	8.21	6.5-8.5
3	Total Dissolve Solids	Mg/L	280	Max 1500
4	Turbidity	NTU	1.37	Max 10
5	E-coli	(cfu)	0	0

29.05.202

Regd. Office : Sangeet CHSL.-12, D-13, Jesal Park, Bhayander (E), Mumbai - 401 105.
Cell : +919821844466, +919323291420
Email : admin@lichens.in

Branch Office : 1st Flr., Dairy Farm, 91, Masoodpu
Vasant Kunj, New Delhi - 110 070.
Cell : +919870333525
Email : lichensindia@hotmail.com
accounts@lichens.in

www.lichens.in